

Date	Manufacturer	Door Type/Ref	Hardware	Glazed	Side	Time to failure (minutes)	Location of failure	Comment from Manufacturer
15/10/2018	E&SW Knowles	DS20WAGCF5XXXXX Finished Door	Door handle	Yes	Opening into furnace	Test stopped after meeting 36	N/A	"E&S W Knowles supply doorsets typically used in commercial buildings where glazing is required to comply with BS 476-22:1987." "MHCLG requested that we provide five locations of installed doorsets and they chose one of these locations. Based on this we had to replicate the exact doorsets to be tested. These were flat entrance doorsets from within the range of our products." "We are pleased to have been involved in the MHCLG fire door investigation and satisfied that our doors conform well above the testing regime standards. This is in line with our product range of 30 minute and 60 minute glazed secure by design fire doors."
18/10/2018	Gerda	Gerda Safer Homes Doorset. Style: Prosper (flush)	Door knocker Spyhole	No	Opening into furnace Opening away from furnace	Test stopped after meeting 36 Test stopped after meeting 36	N/A N/A	"Very pleased with the work carried out by MHCLG on our fire door testing, it shows that working under BM tra 3rd party manufacturing scheme works well, and that clients can have confidence in our fire door."
25/10/2018	West-Port	Thornthwaite Open In Fire Door, FD30s	Door handle Door closer	No	Opening into furnace Opening away from furnace	46 41	Centre of door leaf Top right corner	"We are pleased to have been involved in the MHCLG fire door investigation and satisfied that our doors conform well above the testing regime standards. This is in line with our product range of 30 minute and 60 minute glazed secure by design fire doors."
29/10/2018	SFD Group	FD30s Single Door Set. Door Code SFD/FD30/1450X200 VP	Door handle Door closer	Yes	Opening into furnace Opening away from furnace	Test stopped after meeting 36 Test stopped after meeting 36	N/A N/A	"Very pleased with the work carried out by MHCLG on our fire door testing, it shows that working under BM tra 3rd party manufacturing scheme works well, and that clients can have confidence in our fire door."
29/10/2018	E&SW Knowles	DS20WAGCF5XXXXX Finished Door	Door handle	Yes	Opening away from furnace	Test stopped after meeting 36	N/A	"E&S W Knowles supply doorsets typically used in commercial buildings where glazing is required to comply with BS 476-22:1987." "MHCLG requested that we provide five locations of installed doorsets and they chose one of these locations. Based on this we had to replicate the exact doorsets to be tested. These were flat entrance doorsets from within the range of our products." "We are pleased to have been involved in the MHCLG fire door investigation and satisfied that our doors conform well above the testing regime standards. This is in line with our product range of 30 minute and 60 minute glazed secure by design fire doors."
30/10/2018	Vicaima	Portaro SBD FD30s N1000 Oak Frame Code 610609 Door Code 611	Keyhole Door handle Door closer	No	Opening into furnace Opening away from furnace	54 48	Top left corner Bottom left corner	"As a specialist fire doorset manufacturer, with a long standing commitment to rigorous fire testing and third party accreditation, we welcomed this investigation and believe the MHCLG test vindicates Vicaima's exemplary performance standards for entrance fire doorsets."
11/12/2018	JELD-WEN	FD30 Paint Grade Door (CF192)	Door handle	No	Opening into furnace Opening away from furnace	41 43 (no failure)	Top left corner N/A	N/A
13/11/2018	Door & Joinery Solutions	Internal paint grade fd30 fire door using Strebor 44 core	Door handle Door closer	No	Opening into furnace Opening away from furnace	34 49	Bottom left corner Top centre frame	"Door & Joinery Solutions are happy to have taken part in the MHCLG investigation. The over-performance is indicative of what we would expect to see from a well-constructed, timber doorset when using the Strebor door core from Falcon Panel Products and compatible assessed components and materials. Door & Joinery Solutions certificated under the Certifire scheme. We are committed to third-party certification and understand the importance of manufacturing a high-quality, functional product designed to save lives in the unlikely event that should be required to do so."
14/11/2018	Enfield Specialist Doors	ESD-FD30- Pas24	Door handle Door closer	No	Opening into furnace Opening away from furnace	35 51	Top left corner Door handle	"Enfield Doors were pleased to have been approached and the factory visit by MHCLG personnel was a welcome one. We confidently supplied doorsets typically used in front entrance applications that require both fire, smoke and security performance (despite this having some large metal components that can prove a challenge when fire testing), because of the 3 point locking system. We are Third-Party Certified under IFCC doorset manufacturers' scheme and based our manufactured specification using evidence of a previously tested doorset incorporating Strebor door core, STS seals and ERA hardware. It was positive to witness the test overrun and that the specimen opening away from the furnace performed beyond that of its opening inward counterpart, as it confirmed to us the long established rationale from"
15/11/2018	Deanta	Seville 44mm FD30	Door handle Door closer	No	Opening into furnace Opening away from furnace	42 56	Top left corner Door handle	N/A
16/11/2018	Premdor	Premdor standard residential 30-minute fire doorset	Door handle	No	Opening into furnace Opening away from furnace	50 49	Top hinge Head	N/A
03/12/2018	Arnold Laver	Arnold Laver Internal FD30 Fire Door Set.	Door handle Door closer	No	Opening into furnace Opening away from furnace	45 46	Door handle Door handle	N/A
04/12/2018	Acorn Doorsets	Averta doorset : Averta duo-touch FD30 door frame with Averta laminate FD30 glazed door	Door handle Door closer	Yes	Opening into furnace Opening away from furnace	53 54 (no failure)	Top left corner N/A	"Really pleased to help MHCLG with their testing. Overjoyed to see the first of our FD30 doorset fail at 53 minutes and the other still intact when the test was stopped at 54 minutes."
10/12/2018	Ventro	N/A	Letterbox Door handle Door closer	No	Opening into furnace Opening away from furnace	35 41	Bottom centre frame Bottom centre frame	N/A