

03/12/2018	Arnold Laver	Arnold Laver Internal FD30 Fire Door Set.	Door handle Door closer	No	Opening into furnace Opening away from furnace	45 46	Door handle Door handle	N/A
04/12/2018	Acorn Doorsets	Averta doorset : Averta duo-touch FD30 door frame with Averta laminate FD30 glazed door	Door handle Door closer	Yes	Opening into furnace Opening away from furnace	53 54 (no failure)	Top left corner N/A	"Really pleased to help MHCLG with their testing. Overjoyed to see the first of our FD30 doorset fail at 53 minutes and the other still intact when the test was stopped at 54 minutes."
10/12/2018	Ventro	N/A	Letterbox Door handle Door closer	No	Opening into furnace Opening away from furnace	35 41	Bottom centre frame Bottom centre frame	N/A
11/12/2018	G E Door Manufacturing	Latched, single action, single leaf FD30s	Keyhole Door handle	Yes	Opening into furnace Opening away from furnace	35 50 (no failure)	Top centre frame N/A	N/A
12/12/2018	Doorpac	FD30 Strebord 44	Keyhole Door closer	No	Opening into furnace Opening away from furnace	45 45	Top centre frame Door handle	N/A
13/12/2018	BBatch Group	N/A	Door handle Door closer	Yes	Opening into furnace Opening away from furnace	40 47	Glazing and top centre frame Glazing	N/A
14/12/2018	Ahmarra	Internal timber FD30 fire door	Keyhole Door handle	No	Opening into furnace Opening away from furnace	47 56	Door handle Door handle	"The results confirmed our expectation that Ahmarra's fire doors will not only meet but will far exceed the expected fire resistance requirement. As well as undertaking our own primary fire testing, Ahmarra undergo a rigorous auditing process under BM TRADA – an impartial, third-party certification body. Offering our clients the reassurance of a fully certified and compliant product"
15/12/2018	Russel Timber Technology	QTE2 FD30S Door Set	Door handle	No	Opening into furnace Opening away from furnace	48 (no failure) 47	N/A Bottom left corner	N/A
16/12/2018	Sentry Doors	FED20-44mm including letter plate and eye viewer	Letterbox Door handle Door closer	No	Opening into furnace Opening away from furnace	43 30	Bottom left corner - 14mm hardwood threshold Bottom centre frame - 14mm hardwood threshold	N/A
15/02/2019	Shellen Doors	Enduro Range Doorset	Door knocker Door handle Letterbox Door closer	No	Opening into furnace Opening away from furnace	30 30	Door handle Door handle	N/A
16/02/2019	Birmingham Joinery	535803	Door handle Door closer	No	Opening into furnace Opening away from furnace	49 56	Door handle Bottom centre frame	N/A
23/02/2019	Humphrey & Stretton plc	Vendor44	Door closer	No	Opening into furnace Opening away from furnace	46 59 (no failure)	Top right frame N/A	"At Humphrey & Stretton plc the quality and performance of our product is the most important part of what we do. Through years of product development we have confidence in our product and are delighted this has been proven by the government through this test."
25/02/2019	Shadbolt / Ruddy's Joinery	SHADMASTER 30	Door closer Door handle Keyhole	No	Opening into furnace Opening away from furnace	30 43 (no failure)	Top right corner N/A	N/A
27/02/2019	Doorset Technology	Stairwell Access, Unlatched, Single Acting	Door handle Door closer	Yes	Opening into furnace Opening away from furnace	48 36	Top left corner Bottom left corner	"The achieved performance for both orientations fully endorses the previous and established test results typical for this application and rating, in that opening into the furnace is the most onerous condition. The 20% and 50% performance overruns are also consistent with the extensive bank of proven and reliable primary test evidence for this FD30S timber based doorset system"
16/03/2019	Cotswold Manufacturing Ltd.	Xander - Q-Mark & BBA Doorset	Keyhole Door handle Door closer	Yes	Opening into furnace Opening away from furnace	37 40	Glazing Glazing	"As a fully accredited and certificated manufacturer of fire-rated timber products Cotswold Manufacturing Ltd welcomed and embraced the opportunity of supporting MHCLG by providing timber Doorset specimens in assistance with the Fire Door Investigation. MHCLG have our continued backing in promoting awareness and understanding of the importance of Doorsets, as a lifesaving device, with the need of sourcing said products from a company such as CML that continue to invest in delivering product that exceed standards; which has been demonstrated by the means of the test results exceeding our anticipated 20% overrun in achieving 37-40minutes resistance."